



TO: Leonard Emementary  
RE: 335 E Elmwood; Leonard  
WSSN: 2057463  
PURPOSE: Routine

DATE: April 14, 2023  
SAMPLE #: 62230  
COLLECTED BY: Geoff Todd

### ANALYTICAL REPORT

PARAMETER	Result	Date/Time Sampled		Sample Location	Date/Time Analyzed		Analyst	EPA's MCL / AL	R/L	Testing Method
1. Total Coliform Bacteria	Not Detected	4/11/23	12:08p	Kit Sink 3 Comp	4/11/23	2:06p	VC	0	1 cfu/100ml	9223B
2. E-Coli Bacteria	Not Detected	4/11/23	12:08p	Kit Sink 3 Comp	4/11/23	2:06p	VC	0	1 cfu/100ml	9223B
3. Arsenic	Not Detected	4/11/23	12:13p	POE Treated	4/12/23	11:40a	VC	10 ppb	2 ppb	SM 3113B

AquaTest Laboratories, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed. Reproduction of this analytical report is permitted only in its entirety.